


TAMIL NADU FIRE AND RESCUE SERVICES DEPARTMENT
NO OBJECTION CERTIFICATE

R.C.No. 350/V/2021

Date: 06.09.2021

Licence No.33 /2021



Sub: No Objection Certificate- Bhavan's Rajaji vidyashram No.6, Kilpauk Garden Road, Kilpauk, Chennai-10 –Regarding.

Ref: (1) G.O.No.122, School Edu.(2) Dpt. Date.14.09.2004.
(2) G.O.No.123, School Edu.(2) Dpt. Date.14.09.2004.
(3)Your Application letter dated, 03.09.2021.

Based on the Govt. Order mentioned above and the requisition letter given to the BHAVAN'S RAJAJI VIDYASHRAM at No.6, Kilpauk Garden Road, Kilpauk, Chennai-600 010. Tamil Nadu the building and premises Comprises of Ground + 3 Floors Owned/occupied by Bhavan's Rajaji Vidyashram School have complied with the fire prevention and fire safety requirement in accordance with rule of State Fire Service Rules, and verified on 11.06.2020 in the presence of Mr. P. G. Subramanian. Principal and that the school is granted NOC for a period of One year from 06.09.2021 to 05.09.2022 subject to the conditions stated below.

The above premises Inspected by P.Chidambaram. Station Officer, kilpauk on.03.09.2021

CONDITIONS

- 1.This License is Valid for One Year from the date of issue.
- 2.Fire Safety Systems should be maintained in good working Conditions.
- 3.Mock Drill to be Conducted periodically with the help of local Fire Brigades.
- 4.Any erection of permanent or temporary structure should be intimated to this Department.
- 5.A Trained Fire Service Person preferably retired one should be appointed.
- 6.Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
 - a.Building occupancy capacity should not be more than 4 people per Sq.Metre as per the National Building Code-2005.
 - b.The Staircase treads and flooring shall be treated with rough finish (grooving)to avoid falling of Children.
 - c.As para 6.3 of the BIS Standards Is14435-1997 as the classrooms have only on entrance the capacity of the class rooms shall have to be limited to 45 students.
 - d.Perodical maintenance and care should be taken to maintain all fire protection equipments.
 - e.Mock drill has to be conducted at regular intervals in consultation with the District officer Fire and Rescue Services, Chennai City Central District at Kilpauk.
 - f.Third Floor Temporary shed should be Removed with in 6 moths.

STATION OFFICER.
FIRE AND RESCUE STATION.
KILPAUK CHENNAI-10.

To.
The principal.
BHAVAN'S RAJAJI VIDYASHRAM.
No.6, Kilpauk Garden Road,
Kilpauk, Chennai-600 010.

Copy: District Officer, Central Distrist, kilpauk, Chennai-10.